

Certificate of Product Approval

Certificate Number: 717q

Issue: 01

Texecom Ltd

Bradwood Court
St Crispin Way
Haslingden
Lancashire
BB4 4PW



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Products

CELA0050-2 and CELA1000-2

alarm transmission equipment – supervised premises transceivers

Standards

EN 50136-2:2013

Alarm systems - Alarm transmission systems and equipment - Part 2: Requirements for Supervised Premises Transceiver (SPT)

EN 50131-10:2014

Alarm systems - Intrusion and hold-up systems - Part 10: Application specific requirements for Supervised Premises Transceiver (SPT)

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for BRE Global Ltd.

Chris Hunt
Verifier

11 July 2022
Date of Issue

11 July 2022
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 717q Texecom Ltd

Issue: 01

Alarm Transmission Equipment

Product Name	Description	ATS Category	Security Grade	Environmental Classification	LPCB Ref No.
CELA1000-2	Supervised Premises Transceiver providing a single alarm transmission path via Ethernet	SP2, SP3	2 or 3	II	717q/01
CELA0050-2	Supervised Premises Transceiver providing dual alarm transmission paths via Ethernet primary path and 2G/4G radio alternative path	DP1, DP2, DP3, DP4	2 or 3	II	717q/02

Notes:

1. Use of the WiFi interconnection to the AS is not covered by this certification.
2. For compliance with EN 50131-10: 2014, a 4G antenna cable of 3 m, or less, in length must be used and a CAT5e (or better) Ethernet patch cable of 30 m or less must be used.
3. In order to provide an EN 50136 compliant ATS, the SPT must be used in conjunction with a receiving centre transceiver (RCT) which complies with the requirements of EN 50136-3 and a power supply which complies with the requirements of EN 50131-6.

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Chris Hunt

Verifier

11 July 2022

Date of Issue

11 July 2022

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


